Subject to modification in technic and design. Errors and omissions exo

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)

Optical single and multiturn encoders Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI



X 700 with clamping flange

Features

- Encoder single- or multiturn / SSI / ATEX
- Optical sensing method
- Resolution: singleturn 14 bit, multiturn 13 + 12 bit
- Clamping flange with solid shaft ø10 mm
- Explosion protection per Ex II 2D/2G (ATEX)
- Device class 2 / zone 1 (gas), zone 21 (dust)
- Electronic setting of zero point
- Counting direction input
- Maximum resistant against magnetic fields

Technical data - electrica	al ratings
Reverse polarity protection	ı Yes
Consumption w/o load	≤50 mA (24 VDC)
Initializing time typ.	20 ms after power on
Interface	SSI
Steps per turn	16384 / 14 bit
Absolute accuracy	±0.025 °
Sensing method	Optical
Code	Gray or binary
Code sequence	CW/CCW coded by connection
Inputs	SSI clock Control signals UP/DOWN and zero
Output stages	SSI data: linedriver RS485 Diagnostic outputs push-pull
Interference immunity	DIN EN 61000-6-2
Emitted interference	DIN EN 61000-6-4
Diagnostic functions	Self-diagnosis Multiturn sensing
X 700 - Singleturn	
Voltage supply	1030 VDC
Function	Singleturn
X 700 - Multiturn	
Voltage supply	1030 VDC 5 VDC ±10 %
Function	Multiturn
Number of turns	4096 / 12 bit

Technical data - mechanical design			
Size (flange)	ø70 mm		
Shaft type	ø10 mm solid shaft (clamping flange)		
Flange	Clamping flange		
Protection DIN EN 60529	IP 67		
Operating speed	≤6000 rpm (mechanical) ≤6000 rpm (electric)		
Starting acceleration	≤1000 U/s²		
Starting torque	≤0.4 Nm (+25 °C)		
Admitted shaft load	≤60 N axial ≤50 N radial		
Materials	Housing: stainless steel Flange: stainless steel		
Operating temperature	-25+60 °C		
Relative humidity	95 % non-condensing		
Resistance	DIN EN 60068-2-6 Vibration 10 g, 16-2000 Hz DIN EN 60068-2-27 Shock 200 g, 6 ms		
Explosion protection	Ex II 2G Ex d IIC T6 Ex II 2D		
Weight approx.	1300 g		
Connection	Cable		

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)

Optical single and multiturn encoders Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI

Part number Singleturn Multiturn X 700. X 700. 12 02 Α 02 M 1 Connection Connection 12 Cable 2 m, axial 12 Cable 2 m, axial Cable 5 m, axial Voltage supply / signals Cable 10 m, axial 0 10...30 VDC / gray code 13 bit Cable 20 m, axial 2 10...30 VDC / binary code 13 bit Cable 70 m, axial 4 10...30 VDC / gray code 14 bit Cable 6 m, axial 10...30 VDC / binary code 14 bit 23 Cable 40 m, axial Flange / Solid shaft Voltage supply / signals Clamping flange / ø10 mm, IP 67 10...30 VDC / gray code 13 + 12 bit 10...30 VDC / binary code Design 13 + 12 bit Singleturn 4 10...30 VDC / gray code 12 + 12 bit 5 VDC / binary code 12 + 12 bit Data transfer Flange / Solid shaft Clamping flange / ø10 mm, IP 67 Design Multiturn data bit n-1 Clock frequency f 62.5...1500 kHz 40...60 % Duty cycle of T

Delay time tv

Monoflop time tm

Clock interval tp

150 ns

30 µs

 $26 \mu s + T/2$

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)

Optical single and multiturn encoders Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI

Terminal signif	Terminal significance			
UB	Encoder voltage supply.			
GND	Encoder ground connection relating to UB.			
Data+	Positive, serial data output of differential linedriver.			
Data-	Negative, serial data output of differential linedriver.			
Clock+	Positive SSI clock input. Clock+ together with clock- forms a current loop. A current of approx. 7 mA towards clock+ input means logic 1 in positive logic.			
Clock-	Negative SSI clock input. Clock- together with clock+ forms a current loop. A current of approx. 7 mA towards clock- input means logic 0 in positive logic.			
Zero setting	Input for setting a zero point anywhere within the programmed encoder resolution. The zero setting operation is triggered by a High impulse and has to be in line with the selected direction of rotation (UP/DOWN). Connect to GND after setting operation for maximum interference immunity. Impulse duration >100 ms.			
DATAVALID	Diagnostic output. An error warning is given at level Low. Important: Interferences must be drained by the downstram electronics.			
	Diagnostic output for monitoring the multiturn sensor voltage supply. Upon dropping below a defined voltage level the DV MT output is switched to Low.			
UP/DOWN	UP/DOWN counting direction input. This input is standard on High. UP/DOWN means ascending output data with clockwise shaft rotation when looking at flange. UP/DOWN-Low means ascending values with counterclockwise shaft rotation when looking at flange.			

Terminal assignment			
Core colour	Assignment		
brown	UB		
white	GND		
green	Clock+		
grey	Data+		
blue	Zero setting		
pink	Data-		
yellow	Clock-		
black	DATAVALID		
red	UP/DOWN		
violet	DATAVALID MT		

Trigger level	
SSI	Circuit
SSI-Clock	Optocoupler
SSI-Data	Linedriver RS485
Control inputs	Input circuit
Input level High	>0.7 UB
Input level Low	<0.3 UB
Input resistance	10 kΩ
Diagnostic outputs	Output circuit Push-pull circuit-proof
Output level High	>UB -3.5 V (I = -20 mA)
Output level Low	<0.5 V (I = 20 mA)
Load High / Low	<20 mA




14/6/2016 Subject to modification in technic and design. Errors and omissions excepted.

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)
Optical single and multiturn encoders
Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI

Dimensions



316 Subject to modification in technic and design. Errors and omissions excepted

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)
Optical single and multiturn encoders
Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI

Company: Address:

Check list for EX-approval

In compliance with EU standards 94/9/EG for potentially explosive areas it is imperative that the present checklist is duly completed and that all pending questions relating to explosion protection and application are clarified.

Division:					
In charge:					
Phone:	Phone:				
e-mail:					
Product name:	Version:	Resolution (ppr / code):	Supply voltage:		
Kind of e-connection:	Length of cable (m):	Output circuit:	Special options:		
Responsibility Our customer will receive all relevant information to verify a correct application. Our customer has to clarify all relevant criterions and characteristics. The operator shall be responsible for not exceeding the maximum performance limits of our devices (see data sheet). Device utilization/application (E.g.: Lacquering line, manufacturing tech., gas storing vessel etc.)					
Device group, device c	ategory and zone class	Sification			
Device group			please tick		
Device group II			H		
Category 1 (= Zono 0/20		Ex-atmosphere prevailing			
Category 1 (= Zone 0/20 Category 2 (= Zone 1/21	· · · · · · · · · · · · · · · · · · ·	permanently, long-term or frequently only now and then			
Category 3 (= Zone 2/22	•	<u> </u>			
Zone classification	<u>, </u>				
G (gases)	Zone 0, zone 1, zor	ne 2			
D (dusts)	Zone 20, zone 21, 2				
· · · ·	· · · ·				

14/6/2016 Subject to modification in technic and design. Errors and omissions excepted.

Absolute encoders - SSI

Ex approval Ex II 2D/2G (ATEX)
Optical single and multiturn encoders
Singleturn 14 bit, Multiturn 13 bit ST / 12 bit MT

X 700 - SSI

Check list for EX-approval				
Ignition protection please				
Ex d Flameproof (pressure-proof capsule)				
	rinsic safety			<u></u>
	insic safety			
	•			
Gas explosion gro	ир			
Gases are classified	l into explosion groups. D	anger i	increases from group II A to II C	. please tick
II A Pro	pane			
II B Eth	ylene			
II C Hyd	Irogen, Acetylene			
Temperature class Temperature class	es and groups of explo- Max. surface temperatu operating equipment (°C	re of	Max. ignition temperature of combustible substances (°C)	please tick
T1	450	<i>)</i>	> 450	void
T2	300		>300< 450	void
T3	200		>200< 300	void
T4 (on request)	135		>135< 200	Void
T5	100		>100< 135	void
T6	85		> 85< 100	
				to be clarified to be clarified
Mechanical strain				
Rotation speed (rpm	1)			
Axial shaft load (N)				
Radial shaft load (N)				
Ambient impacts (salt, lye, etc.)				
Date		Signatu	re	
Stamp:				
Date	- F	Release	e EExB / trained sales	

