## **Features**


- 1-channel
- · AC version
- Working voltage 6.5 V at 10  $\mu A$
- Series resistance max. 56  $\Omega$
- Fuse rating 100 mA
- · DIN rail mounting

## **Function**

The Zener Barrier prevents the transfer of unacceptably high energy from the safe area into the hazardous area.

The zener diodes in the Zener Barrier are connected in the reverse direction. The breakdown voltage of the diodes is not exceeded in normal operation. If this voltage is exceeded, due to a fault in the safe area, the diodes start to conduct, causing the fuse to blow. The Zener Barrier has alternating polarities, i. e. interconnected zener diodes are employed and one side is grounded. The Zener Barrier can be used for both alternating voltage signals and direct voltage signals.


## **Assembly**








## Connection





Zone 2 Div. 2

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Release date 2014-11-04 10:22 Date of issue 2015-02-16 071773\_eng.xml

my pue
7
75
C dissifu
Т
1
2014-11
Bolosco date

General specifications	
Type	AC version
Electrical specifications	AC VEISION
·	50.0
Nominal resistance	50 Ω
Series resistance	max. 56 $\Omega$
Fuse rating	100 mA
Hazardous area connection	
Connection	terminals 1, 2
Safe area connection	
Connection	terminals 7, 8
Working voltage	max. 8.8 V , 6.5 V at 10 $\mu A$
Conformity	
Degree of protection	IEC 60529
Ambient conditions	
Ambient temperature	-20 60 °C (-4 140 °F)
Storage temperature	-25 70 °C (-13 158 °F)
Relative humidity	max. 75 %, without moisture condensation
Mechanical specifications	
Degree of protection	IP20
Connection	self-opening connection terminals,
	max. core cross-section 2 x 2.5 mm <sup>2</sup>
Mass	approx. 150 g
Dimensions	12.5 x 115 x 110 mm (0.5 x 4.5 x 4.3 in)
Construction type	modular terminal housing , see system description
Mounting	on 35 mm DIN mounting rail acc. to EN 60715:2001
Data for application in connec	
with Ex-areas	
EC-Type Examination Certificate	BAS 01 ATEX 7005, for additional certificates see www.pepperl-fuchs.com
Group, category, type of prote	tion $\textcircled{E}$ II (1)GD, I (M1) [Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I (-20 °C $\leq$ T <sub>amb</sub> $\leq$ 60 °C) [circuit(s) in zone 0/1/2]
Voltage	9.94 V
Current	203 mA
Power	7 <sub>0</sub> 500 mW
Supply	
Maximum safe voltage	l <sub>m</sub> 250 V
Series resistance	min. $49\Omega$
Permissible connection values [E	x ia]
Statement of conformity	TÜV 99 ATEX 1484 X, observe statement of conformity
Group, category, type of prote temperature class	-
Directive conformity	
Directive 94/9/EC	EN 60079-0:2012, EN 60079-11:2012 , EN 60079-15:2010
International approvals	
FM approval	
Control drawing	116-0118
<u> </u>	110-0110
UL approval	116-0139
Control drawing	110-0109
CSA approval	116.0110
Control drawing	116-0119
IECEx approval	IECEx BAS 09.0142
Approved for	[Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I
General information	
Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-fuchs.com.

Singapore: +65 6779 9091 pa-info@sg.pepperl-fuchs.com