



Model Number

SB4-OR-4CP-4C


Safety control unit

Safety control unit of series SB4


Features

- Evaluation device for safety thru-beam sensors SLA12 and SLA29 and for 2 channel safety devices (emergency off)
- 8 sensor channels
- Self-monitoring (type 4 according to IEC/EN 61496-1)
- Operating mode can be selected by means of DIP switches
- Start/Restart disable
- Relay monitor
- Pre-fault indication
- Clearly visible LED functional display
- 7-segment diagnostic display
- Safety outputs OSSD, external status displays OSSD

Dimensions



Electrical connection



Terminal	Function
1	Reset input; normally closed contact
2	Restart input (RI); normally closed contact
3	24 V DC connection for reset, restart and RM
4	Relay monitor (RM)
5 - 6	OSSD1; potential free relay contact; normally open contact
7 - 8	OSSD2; potential free relay contact; normally open contact
9	Signal output OSSD OFF
10	Signal output OSSD ON
11	Signal output restart
12	Leave free (n.c.)
13	+24 V DC supply voltage
14	0 V DC supply voltage
15	Earth
16	Leave free (n.c.)

Terminal	Function	Channel assignment
1	Receiver 2 input	Channel 2
2	Receiver 2 +U	
3	Transmitter 2 +U	Channel 1
4	Transmitter 2 output	
5	Receiver 1 input	Channel 3
6	Receiver 1 +U	
7	Transmitter 1 +U	Channel 4
8	Transmitter 1 output	
9	Transmitter 3 output	Channel 2
10	Transmitter 3 +U	
11	Receiver 3 +U	Channel 1
12	Receiver 3 input	
13	Transmitter 4 output	Channel 3
14	Transmitter 4 +U	
15	Receiver 4 +U	Channel 4
16	Receiver 4 input	

Technical data

General specifications

Operating mode Start/restart disable, relay monitor,

Functional safety related parameters

Safety Integrity Level (SIL) SIL 3
 Performance level (PL) PL e
 Category Cat. 4
 Mission Time (T_M) 20 a
 PFH_d 3.5 E-9
 Type 4

Indicators/operating means

Diagnostics display 7-segment display
 Function display LED red: OSSD OFF
 LED green: OSSD ON
 Yellow LED: start readiness channel 1 - 8
 LED yellow: switching state (receiver)
 Pre-fault indication LED yellow flashing: Indicator lamp channel 1 ... 8

Electrical specifications

Operating voltage U_B 24 V DC, ± 20 %
 No-load supply current I₀ max. 500 mA

Input

Activation current approx. 7 mA
 Activation time 0.4 ... 1.2 s
 Test input Reset-input for system test

Output

Safety output 2 relay outputs, force-guided NO-contact
 Signal output Output for displaying the switching state of the OSSDs
 Switching voltage 10 V ... 250 V AC/DC
 Switching current min. 10 mA , max. 6 A AC/DC
 Switch power DC: max. 24 VA
 AC: max. 230 VA
 Response time 38 ms

Ambient conditions

Ambient temperature 0 ... 50 °C (32 ... 122 °F)

Release date: 2011-06-15 14:42 Date of issue: 2011-06-27 180325_eng.xml

Storage temperature	-20 ... 70 °C (-4 ... 158 °F)
Mechanical specifications	
Protection degree	IP20
Connection	screw terminals , lead cross section 0.2 ... 2 mm ²
Material	
Housing	Polyamide (PA)
Mass	430 g
Compliance with standards and directives	
Standard conformity	(extract)
Standards	EN IEC 61496-1 EN IEC 61508 EN ISO 13849-1
Approvals and certificates	
SIL classification	up to SIL3 acc. to IEC 61508 tested and certified by TÜV SÜD according to: IEC 61508:1998 part 1, 3.4 IEC 61508: 2000 ISO 13849-1:2006 EN 50178:1997 IEC 61496-1:2004 IEC 61496-2:2006
UL approval	cULus
TÜV approval	TÜV

Function

The evaluation system SB4 is an ESPE of type 4 (EN 61496-1 or IEC 61496-1) or category 4 (EN 954-1). This system is also designed and tested according to IEC 61508. It meets the requirements for the SIL3.

The operating instructions supplied with the device must be observed for planning, installation and operation.

A maximum of 8 safety light barriers can be connected to the evaluation device. Instead of the light barriers, other contact safety equipment can be connected.

Operating modes

By default, the restart interlock is activated.

Each assembly contains DIP switches for selecting the functions. For selecting functions, 2 selector switches must always be actuated.

Switches on the first assembly:

switch	Position	Operation type
1 and 3	OFF	Without restart interlock (restart, RI)
	ON	With restart interlock (restart, RI)
2 and 4	OFF	Without relay monitor (RM)
	ON	With relay monitor (RM)

Switches on the second assembly:

switch	Position	Operation type
1 and 3	OFF	No antivalent evaluation
	ON	Antivalent evaluation active
2 and 4	OFF	No simultaneousness evaluation
	ON	Simultaneousness evaluation active

Displays

The OSSD-R/supply module on position 1 has a red/green LED for indicating the OSSD on/off statuses, a yellow LED for the start-ready status and a 7 segment display for system diagnosis.

The 7 segment display indicates the status and the error codes of the system.

Display	7 segment display
1	DIP switch position does not match
2	Incorrect configuration
3	Time-out at one or more muting sensors
4	Transmitter error
6	Muting lamp error
7	Simultaneousness monitoring error

Release date: 2011-06-15 14:42 Date of issue: 2011-06-27 180325_eng.xml

8	Receiver error
9	Error at sensor channel
E	System error
F	Relay monitor error
H	Selection chain error
U	Low voltage or voltage surge detected