

# **Model Number**

# UBE1000-18GM40-SE2-V1


Single head system

### **Features**

- Short design, 40 mm ٠
- Function indicators visible from all directions
- Switch output
- **Program input**
- Integrated alignment aid

## Diagrams

## Characteristic response curve



**Technical data** 

**General specifications** Sensing range Standard target plate Transducer frequency Indicators/operating means LED green LED yellow LED red **Electrical specifications** Operating voltage U<sub>B</sub> No-load supply current I<sub>0</sub> Time delay before availability t Input Input type Output Output type Rated operating current Ie Voltage drop U<sub>d</sub> Switch-on delay ton Switching frequency f Ambient conditions Ambient temperature Storage temperature Mechanical specifications Connection type Degree of protection Material Housing Transducer

Mass Compliance with standards and directives Standard conformity Standards

#### Approvals and certificates

UL approval CSA approval CCC approval

15 ... 1000 mm 100 mm x 100 mm approx. 255 kHz

Power on switching state error, object uncertain

10 ... 30 V DC , ripple 10 %<sub>SS</sub> ≤ 20 mA  $\leq$  200 ms

1 program input free air path: -U<sub>B</sub> ... +1 V, object: +6 V ... +U<sub>B</sub> input impedance: > 4,7 k  $\Omega$  program pulse:  $\geq$  1 s

PNP, NO 200 mA , short-circuit/overload protected  $\leq$  3 V < 5 ms  $\leq$  100 Hz

-25 ... 70 °C (-13 ... 158 °F) -40 ... 85 °C (-40 ... 185 °F)

Connector M12 x 1 , 4-pin IP67

brass, nickel-plated epoxy resin/hollow glass sphere mixture; foam polyurethane, cover PBT 25 g


EN 60947-5-2.2007 IEC 60947-5-2:2007

cULus Listed, General Purpose cCSAus Listed, General Purpose CCC approval / marking not required for products rated ≤36 V

PEPPERL+FUCHS

1

# **Dimensions**



Date of issue: 2015-02-12 205346\_eng.xml Release date: 2015-02-12 14:45

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com


Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



800

1000

tance X [mm]



The function of through-beam ultrasonic barriers is not dependent on the position of

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com

their installation. We recommend, however, to install the emitter below in the case of vertical installations to prevent the accumulation of dust particles.

# Startup and parameterising

For easy alignment of emitter and receiver towards each other, the receiver is equipped with an alignment aid. To activate the alignment aid, the TEACH-Input of the receiver (pin 2) has to be connected to ground  $(-U_B)$ . The flashing frequency of the yellow LED indicates the strength of the received ultrasonic signal. The better the alignment, the stronger the signal.

LED yellow, flashing frequency	Description
slowly (appr. 1.5 Hz)	no signal
medium (appr. 3 Hz)	weak signal
fast (appr. 9 Hz)	strong signal

Simultaneously the ultrasonic barrier evaluates the signal strength of the unobstructed signal path and generates the optimal switching threshold. When disconnecting the TEACH-input from  $-U_B$ , this threshold is stored non-volatile in the receivers memory. In case of clear ultrasonic path (no object), only the receivers green LED is on.

### **TEACH-In of very small objects/obstacles**

Like shown in the curve "obstacle size", the ultrasonic barrier offers the possibility to detect very small objects at a distance of more than 300 mm.

- place the object to be detected in the desired distance inside the ultrasonic path

- connect TEACH-input of the receiver to +U<sub>B</sub> (yellow LED flashes slowly)

- disconnect TEACH-input

In case of successful TEACH-IN (object is detected reliable), the yellow LED is on and the taught detection threshold is stored non-volatile to the receivers memory.

In case of unsuccessful TEACH-IN (object too small or too porous for ultrasonic sound), the red LED flashes 5 times and the ultrasonic barrier continues normal operation with unmodified detection threshold value.

## **Test function**

For test purpose, the ultrasonic emitter is equipped with a test input. In normal operation mode (test input not connected or connected to  $-U_B$ ), the green LED of the emitter is on. If the test input is connected to  $+U_B$ , the ultrasonic emitter gets deactivated and its LED changes into red. Simultaneously the receiver switches and its yellow LED goes on.

