











# **Dimensions**





#### Model number


#### **VBG-PNS-K30-DMD**

PROFINET Gateway, PROFIsafe for 2 AS-Interface networks


#### **Features**

- Gateway and safety monitor in one housing
- Gateway compliant with AS-Interface specification 3.0
- Connection to PROFINET IO
- AS-Interface safety monitor with extended range of functions
- Certified up to SIL 3 according to IEC 61508 and EN 62061 and up to PL<sub>e</sub> according to EN 13849
- Memory card for configuration data
- 2 AS-Interface networks
- 2 safe output relays and 2 safe electronic outputs
- PROFIsafe protocol for centralized and secure higher-level control

# **Electrical connection**



# **Indicating / Operating means**



#### **Technical data**

General	specifications
---------	----------------

AS-Interface specification V3.0

Duplicate address detection from AS-Interface slaves

Earth fault detection EFD integrated EMC monitoring integrated

Diagnostics function Extended function via display

Switch-on delay < 10 s

#### Functional safety related parameters

#### Indicators/operating means

Display Illuminated graphical LC display for addressing and error mes-

sages

LED ETHERNET PROFINET master detected; LED green
LED AS-i ACTIVE AS-Interface operation normal; LED green

LED CONFIG ERR configuration error; LED red
LED PRG ENABLE autom. programming; LED green

LED POWER voltage ON; LED green

 LED PRJ MODE
 projecting mode active; LED yellow

 LED U AS-i
 AS-Interface voltage; LED green

 LED AUX
 ext. auxiliary voltage U<sub>AUX</sub>; LED green

LED EDM/Start Input closed, 4x yellow LEDs
LED output circuit Output circuit closed; 4 x green LEDs

Button 4

#### **Electrical specifications**

Insulation voltage U<sub>i</sub> ≥ 500 V

Rated operating voltage  $U_e$  26.5 ... 31.6 V from AS-Interface; Output K3 and K4 24 V  $_{
m DC}$ 

Rated operating current  $I_{e} \leq 300$  mA off AS interface network 1  $\leq 300$  mA off AS interface network 2

< 370 mA in total

#### Interface 1

Interface type PROFINET I / O device (IRT)

Physical 2 x RJ-45

Protocol Media Redundancy Protocol (MRP)

Transfer rate 10 MBit/s / 100 MBit/s , Automatic baud rate detection

# Interface 2

Interface type RS 232, serial Diagnostic Interface

Transfer rate 19,2 kBit/s

#### Interface 3

Interface type Chip card slot

# Input

Number/Type 4 EDM/Start inputs:

EDM: Inputs for the external device monitoring circuits

Start: start inputs:

Static switching current 4 mA at 24 V, dynamic 30 mA at 24 V

(T=100 μs)

# Output

Safety output Output circuits 1 and 2: 2 potential-free contacts,

max. contact load: 3  $A_{DC-13}$  at 30  $V_{DC}$ , 3  $A_{AC-15}$  at 30  $V_{AC}$ 

Output circuits 3 and 4: 2 PNP transistor outputs

max. contact load: 0.5 A<sub>DC-13</sub> at 30 V<sub>DC</sub>

# Connection PROFINET AS-Interface

PROFINET RJ-45

spring terminals, removable

#### Ambient conditions

Ambient temperature  $0 \dots 55$  °C (32  $\dots$  131 °F) Storage temperature  $-25 \dots 85$  °C (-13  $\dots$  185 °F)

#### **Mechanical specifications**

Degree of protection IP20 Mass 800 g

Construction type Low profile housing , Stainless steel

#### Compliance with standards and directi-

#### ves .

Directive conformity

EMC Directive 2004/108/EC EN 61000-6-2:2005, EN 61000-6-4:2007

Standard conformity

Electromagnetic compatibility EN 61000-6-2:2005, EN 61000-6-4:2007

AS-Interface EN 50295:1999
Degree of protection EN 60529:2000
Shock and impact resistance EN 61131-2:2004

The VBG-PBS-K30-DMD is a PROFINET gateway with a safety monitor controlled via PROFIsafe and a double master according to AS-Interface specification 3.0 with a degree of protection IP20.

**Function** 

The gateway has four inputs and four outputs. The four inputs are used either for extended EDM device monitoring or as start inputs. Two sets of two outputs act as relay outputs and switch output circuits 1 and 2 and, as semiconductor outputs, output circuits 3 and 4. The K30 model is particularly suitable for installation in a control cabinet.

The gateway is used to connect AS-Interface systems to a higher-level PROFINET. It acts as a master for the AS-Interface segment and as a slave for the PROFINET. During cyclic data exchange, the digital data of an AS-Interface segment is transferred. Analog values as well as the complete command set of the new AS-Interface specification are transferred via PROFINET using a command interface.

Configuration of the device can be performed using switches. Seven LED located on the front panel indicate the current status of the AS-Interface segment. One LED shows the power supply via AUX. A further eight LEDs indicate the status of the inputs and outputs.

With the graphical display, the commissioning of the AS-Interface circuits and testing of the connected peripherals can take place completely separately from the commissioning of the higher-level network and the programming. Four switches allow all the functions covered on the other AS-Interface masters by AS-i Control Tools software to be visualized on the display. An RS 232 socket provides a way of exporting data relating to the gateway, network and operation directly from the gateway for extended local diagnosis purposes.

The device has a card slot for a memory card for the storage of configuration data.

An integrated Switch and 2 RJ-45 sockets allow the design of a line topology without the use of an external Switch.

An integrated webserver allows to administrate the device and The AS-interface network without additional hard and/or software via a browser interface.

The redundant power supply guarantees that the double master remains in function and is diagnosticable, when a failure of a power supply unit in one of the two AS-interfaces circles occures. Also communication with the superior field bus is not disturbed by the failure of a power supply.

#### **Accessories**

### **VAZ-SW-SIMON+**

Software for configuration of K30 Master Monitors/K31 and KE4 Safety Monitors

# **USB-0,8M-PVC ABG-SUBD9**

Interface converter USB/RS 232

Release date: 2014-03-10 11:29 Date of issue: 2014-03-10 220393\_eng.x

Standards

EN 61000-6-2:2005, EN 61000-6-4:2007 EN 954-1:1996 (up to Kategorie 4), IEC 61508:2001 and EN 62061:2005 (up to SIL3) EN 13849:2008 (PL e)

# **Notes**

In an AS-Interface network only one device can be operated earth fault detection. If there are many devices in an AS-Interface network, this can lead to the earth fault monitoring response threshold becoming less sensitive.