



Features

- · Cast Aluminium
- Installation in Zone 1, Zone 2, Zone 21 and Zone 22
- · Threaded cable entries
- · Padlockable switch

Technical data

Dimensions (mm)





Electrical specifications	
Operating voltage	690 V
Operating current	100 A (AC21A)
Power	37 kW (AC23A) 30 kW (AC3)
Terminal capacity	50 mm ²
Function	switch disconnetor
Number of poles	4
Auxiliary contacts	2 x n/o early break
Lockable	in 'OFF' position
Labeling	OFF - ON
Mechanical specifications	
Height	210 mm NOM.
Width	185 mm NOM.
Depth	200 mm NOM.
Enclosure cover	hinged non-detachable
Cover fixing	M6 stainless steel socket cap head screws
Fastener grade	A2-70
Protection degree	IP66
Cable entry	metric threaded
Number of cable entries	1 x M25 in face A 2 x M25 in face B all entries are fitted with Ex d sealing plugs
Material	
Enclosure	cast aluminium
Finish	painted black
Seal	one piece closed cell neoprene

approx. 8 kg

_
e
Ψ
$\overline{}$
Ġ
437891
w
\sim
'n
6.5
4
-
9
_
٠,
_
<u>`</u>
$^{\circ}$
(T)
_
_
$\mathbf{\mathcal{L}}$
ťΛ
a
$\underline{\Psi}$
\neg
S
ťΛ
.==
$\overline{}$
U
a
7
LU.
\sim
\Box
Date of issue 2013-01-16
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12
2013-01-16 13:12

Mounting	2 x fabricated stainless steel mounting straps
Grounding	internal & external brass grounding terminals on base and lid
Ambient conditions	
Ambient temperature	-20 55 °C (-4 131 °F)
Data for application in connection with Exareas	
EC-Type Examination Certificate	SIRA 03 ATEX 1215
Group, category, type of protection, temperature class	
International approvals	
IECEx approval	IECEx SIR 08.0055
GOST-R approval	GOST-R B01008
Conformity	
Protection degree	EN 60529
Switch	switch disconnector to IEC 60947-3
General information	
Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperl-fuchs.com