



Features

- · Cast Iron
- Installation in Zone 1, Zone 2, Zone 21 and Zone 22
- Threaded cable entries
- · Padlockable switch

Dimensions (mm)





Te	chr	nical	data

Electrical specifications	
Operating voltage	690 V
Operating current	100 A (AC21A)
Power	37 kW (AC23A) 30 kW (AC3)
Terminal capacity	50 mm ²
Function	switch disconnetor
Number of poles	6
Auxiliary contacts	2 x n/o early break
Lockable	in 'OFF' position
Labeling	OFF - ON
Mechanical specifications	
Height	335 mm NOM.
Width	310 mm NOM.

Width	310 mm NOM.
Depth	253 mm NOM.
Enclosure cover	hinged non-detachable
Cover fixing	M6 stainless steel socket can head s

Cover fixing	M6 stainless steel socket cap head scre
Fastener grade	A2-70

Protection degree	IP00
Cable entry	metric threaded
Number of cable entries	3 x M25 in face B
	all entries are fitted with Exid sealing plugs

	all entries are fitted with Ex d sealing plug
Material	

Enclosure	cast iron
Finish	painted black
Seal	one piece closed cell neoprene
Mass	approx. 50 kg

Mass	approx. 50 kg
Mounting	2 x fabricated stainless steel mounting strap

7
ō
9
Ō
œ
437896
m
₹
4
1-16
w
Τ.
Ξ
Ó
~
(,)
Ξ
0
Ñ
a
~
ಸ
77
. <u></u>
•
Ö
Φ
≒
Ω
Date of issue 2013-01-
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
2013-01-16 13:10
ate 2013-01-16 13:10

Grounding	internal & external brass grounding terminals on base and lid
Ambient conditions	
Ambient temperature	-40 55 °C (-40 131 °F)
Data for application in connection with Exareas	
EC-Type Examination Certificate	SIRA 04 ATEX 1266X
Group, category, type of protection, temperature class	⟨⟨ω⟩ II 2 GD Ex d IIB T5 Gb, Ex tb IIIC T82°C Db (ta +55°C)
International approvals	
IECEx approval	IECEx SIR 08.0056X
GOST-R approval	GOST-R B01008
Conformity	
Protection degree	EN 60529
Switch	switch disconnector to IEC 60947-3
General information	
Supplementary information	EC-Type Examination Certificate, Statement of Conformity, Declaration of Conformity, Attestation of Conformity and instructions have to be observed where applicable. For information see www.pepperlfuchs.com.