SIEMENS



Heating Controller

including d.h.w. heating

RVL482

Multifunctional and communicating heating controller for use in residential and non-residential buildings. Suited for heating circuit control with demandcompensated boiler temperature control or precontrol. Suited for modulating or 2-stage burners. Control of d.h.w. heating. 21 programmed plant types. Operating voltage AC 230 V

036	
	 Types of houses and buildings: Multifamily houses Single-family houses Non-residential buildings Types of plants: Heating zones including d.h.w. heating with own heat source Interconnected plants consisting of heat source, several heating zones and central or decentral d.h.w. heating plant Types of heating systems: Radiator, convector, underfloor and ceiling heating systems, or radiant panels
Functions	
Heating zone control	 Weather-compensated flow temperature control through control of the mixing valve in one of the heating zones Weather-compensated flow temperature control through control of the mixing valve and demand-compensated control of the boiler temperature through control of the burner in one of the heating zones Weather-compensated flow temperature control through control of the mixing valve and demand-compensated control of the boiler temperature through control of the burner in one of the heating zones Weather-compensated flow temperature control through control of the mixing valve and demand-compensated control of the boiler temperature through control of the burner in one of the heating zones; with separate mixing valve for minimum limitation of the boiler return temperature

Precontrol	 Demand-compensated control of the boiler temperature through control of the burner; heat demand signal via data bus Demand-compensated control of the boiler temperature through control of the burner; heat demand signal via data bus; with separate mixing valve for minimum limitation of the boiler return temperature
D.h.w. heating	 D.h.w. heating: Through control of the charging pump Through control of the mixing valve Via heat exchanger through control of the valve in the primary return Via solar collector Control of a circulating pump and of an electric immersion heater
Operating modes	Auto Automatic mode Automatic changeover from the NORMAL to the REDUCED room temperature, and vice versa, according to the 7-day program, automatic changeover to holiday mode, demand-compensated control of the heating system (ECO function)
	(Setback mode
	Continuous heating to the REDUCED temperature (with ECO function)
	Continuous heating to the NORMAL temperature (without ECO function)
	Protection
	Automatic d.h.w. heating
	Manual operation No control, circulating pumps in service
	Frost protection is ensured in all operating modes.
Other functions	 Optimization functions Protective functions Remote control Commissioning tools Communication functions
Ordering	
	When ordering, please give type reference RVL482 . The controller is supplied complete with Operating Instructions and Installation Instruc- tions. Sensors and, if required, room unit, actuator and valve must be ordered as separate items.

Product documentation

Type of documentation	Document no.	Part no.
Basic Documentation	P2542	_
Installation Instructions (languages: de, en, fr,	G2542	74 319 0619 0
nl, sv, fi, da, it, es)		
Operating Instructions (languages: de, en, fr,	B2540	74 319 0616 0
nl, sv, fi, da, it, es)		
CE Declaration of Conformity	T2540	
Environmental Declaration	E2542	_

Suitable sensors and room units	 Flow , return and d.h.w. temperature: All sensors with sensing elements LG-Ni 1000, for example: Strap-on temperature sensor QAD22 Immersion temperature sensor QAE212 or QAP21.3 Collector temperature sensor (solar) QAP21. Room temperature: Room unit QAW50 or QAW70 Room temperature sensor QAA24 Outdoor temperature: Outside sensor QAC22 (LG-Ni 1000 sensing element) Outside sensor QAC32 (NTC 575 sensing element) Wind sensor (commercially available, DC 010 V) Solar impact sensor QLS60
Suitable actuators	All electromotoric and electrohydraulic actuators for 3-position control made by Siemens can be used.
Communication	The controller can communicate with:All LPB-compatible devices made by SiemensThe SYNERGYR OZW30 central unit (software version 3.0 or higher)
Note	The heating controller RVL482 cannot be used as partner unit for the RVL469!

Technical design

Plant types

Heating aircuit plant types	4	
Heating Circuit plant types	 Heating circuit control with mixing group Can be combined with d.h.w. types: with types 1, 2 and 3 via hydraulic connection at O and D with type 4 without hydraulic connection 	
	 2 Heating circuit control with mixing group, boiler control Can be combined with d.h.w. types: with types 1, 2 and 3 via hydraulic connection at ○ and □ with type 4 without hydraulic connection 	
	 3 Heating circuit control with mixing group, boiler control, maintained boiler return temperature with mixing valve Can be combined with d.h.w. types: with type 1 via hydraulic connection at ○ and □ with type 4 without hydraulic connection 	B ³ LPB M1 M2 E ¹ B7 M2 E ² M2 E ² M2 M2 M2 M2 M2 M2 M2 M2 M2 M2
	 4 Precontrol with boiler Can be combined with d.h.w. types: – with types 1, 2 and 3 via hydraulic connection at ○ and □ – with type 4 without hydraulic connection 	E1 B2 M1 B7 J, 2, 3
	 5 Precontrol with boiler, maintained boiler return temperature with mixing valve Can be combined with d.h.w. types: – with type 1 via hydraulic connection at ○ and □ – with type 4 without hydraulic connection 	

D.h.w. circuit plant types

0	
No d.h.w. heating	
 1 D.h.w. heating with charging pump (optional solar and/or electric immersion heater) Note: Circulating pump M4 only with heating circuit types 1, 2 and 4 Electric immersion heater not possible with modulating burner 	

	 2 D.h.w. heating with mixing group (optional solar and/or electric immersion heater) Note: Circulating pump M4 only with heating circuit types 1, 2 and 4 Electric immersion heater not possible with modulating burner 	NI V7 M3 K6 B31 B31 B31 B31 B31 M4 M5
	 3 D.h.w. heating with heat exchanger Note: Circulating pump M4 only with heating circuit types 1, 2 and 4 	M W Y7 W Y7
	 4 D.h.w. heating with electric immersion heater (optional solar heating) Note: Circulating pump M4 only with heating circuit types 1, 2 and 4 Electric immersion heater not possible with modulating burner 	
	A6Room unitLPIB1Flow sensorK6B2Boiler sensorM1B3Flow sensor for d.h.w.M2B31D.h.w. storage tank sensor / control thermostat 1M3B32D.h.w. storage tank sensor / control thermostat 2M4B5Room sensorM5B6Collector sensorN1B7Return sensorU1B9Outside sensorU2E1Heat source (boiler)Y1E2Load (space)Y7	 B Data bus Electric immersion heater Circulating pump / bypass pump Heating circuit pump Charging pump Boiler pump / circulating pump Collector pump Controller RVL482 Solar impact sensor Wind sensor Heating circuit mixing valve D.h.w. mixing or 2-port valve, or mixing valve for minimum limitation of the boiler return temperature
Working principle	The RVL482 offers 5 different plant types for s types for d.h.w. heating all of which are ready p plant types, a total of 21 plants can be configur When commissioning the system, the appropri control and d.h.w. heating need to be entered. the respective type of plant. The default setting All functions that are not required for the config are deactivated.	pace heating and precontrol, and 4 plant programmed. By combining the different red. ate plant types for space heating / pre- This activates all functions required for gs are practice-oriented. gured plant type will not be shown and
Enduser settings	 With weather-compensated control, the flow tere curve as a function of the outdoor temperature bar on the front of the unit or on an operating ling justed with the setting knob. In addition, following can be entered by the endered by the room temperature setpoints of NORMA frost protection / holidays The d.h.w. temperature setpoints 2 independent 7-day switching programs an year The operating mode The time of day and the date 	mperature is controlled via the heating . Its basic setting is made with the little ne. The room temperature can be read- duser: L heating, REDUCED heating and d a maximum of 8 holiday periods per

Temperature acquisition	 Flow temperature: with LG-Ni 1000 sensor Outdoor temperature: with LG-Ni 1000 or NTC 575 sensor; the RVL482 automatically identifies the type of sensor used. In interconnected plants, it is also possible to identify the source of the outdoor temperature Room temperature: With a room sensor or room unit, or both (averaging)
Space heating	 The room temperature is included in the control. It can be acquired with a sensor or can be simulated by a room model that uses an adjustable building time constant. When using a sensor, the impact on the control can be adjusted. It is also possible to limit the maximum room temperature The influence of solar radiation and/or wind can be acquired by a solar impact and/or wind sensor, which is then included in the control. The authority of both is adjustable. In interconnected plants, the sensor signals can be provided from external locations via data bus The heating is switched on and off depending on demand (ECO function). It is switched off when the amount of heat stored in the building structure is sufficient to maintain the required room temperature and the building's heat storage capacity. It is possible to set 2 heating limits, one for NORMAL heating and one for REDUCED heating The control is optimized. Switching on, heating up and shutting down are controlled such that, during occupancy times, the required room temperature is always maintained. At the end of each occupancy period, the heating will be shut down (circulating pump) until the room temperature setpoint for the nonoccupancy time is reached (quick setback, can be deactivated). During heating up time and for early shutdown
3-position control	3-position control operates as weather-compensated flow temperature control. P-band and integral action time are adjustable. The flow temperature is controlled via the con- trolling element (seat or slipper valve). Minimum and maximum limitation of the flow temperature as well as maximum limita- tion of the rate of setpoint rise are adjustable.
Boiler temperature control	Boiler temperature control is demand-compensated. If there is no demand for heat, the boiler will either be shut down or maintained at the minimum limit value (selectable). Minimum and maximum limitation of the boiler temperature are adjustable. With regard to the heat source, a differentiation is made between multistage and modulating burners. The type of heat source can be selected.
Multistage burner	In the case of a multistage burner, the boiler temperature is controlled through 2- position control. The boiler temperature is controlled by activating and deactivating the single- or 2-stage burner (direct burner control). 2-stage operation is enabled when the release limit of burner stage 2 is reached, and disabled when the reset limit of burner stage 2 is reached. The limits can be adjusted.
Modulating burner	In the case of a modulating burner, boiler temperature control is achieved through activation and deactivation of the burner and control of the burner's modulating actuator (PID mode). P-band, integral action time and derivative action time are adjustable. Modulation is activated during the second stage of the 2-stage burner.

Minimum limitation of the return temperature	 Minimum limitation of the return temperature protects the boiler against flue gas condensation. With the RVL482, this function can be implemented in 3 different ways: Lowering of the consumers' flow temperature setpoint Use of a bypass pump (only with plant types 2–x and 4–x) Own mixing value in the boiler return (only with plant types 3–x and 5–x)
Maximum limitation of the return temperature	 The RVL482 offers 2 types of return temperature maximum limitation: With plant types 1–x: Limitation acts on the setpoint of the heating circuit's flow temperature With plant types 2–x and 4–x: Limitation acts on the boiler temperature setpoint (suited for bivalent plants)
Locking functions	On the software side, all settings can be locked to prevent tampering.
Time switches	 The RVL482 has 3 independent 7-day time switches whose assignment can be selected. Each 7-day time switch affords 3 daily on periods, which may differ from one weekday to the other. The heating circuit, d.h.w. heating, circulating pump and multifunctional relay can be assigned to one of the three 7-day time switches For entering a maximum of 8 holiday periods, the RVL482 is equipped with a yearly time switch featuring automatic summer-/wintertime changeover
D.h.w. heating	 D.h.w. heating source can be Boiler Heat exchanger Precontroller Solar collector (charging is shown in the LCD with %) Electric immersion heater (summer operation) D.h.w. heating is controlled independent of the heating circuit. Charging to the NORMAL or REDUCED d.h.w. setpoint can be adjusted to meet individual needs. It can be released: According to its own 7-day program According to the switching program of the heating circuit (one hour before space heating starts) According to the switching programs of the zone controllers on the data bus Continuously (24 hours a day) D.h.w. heating features a legionella function that can be deactivated. It is activated at a pre-determined date and time and for a selected duration. The d.h.w. temperature is acquired: With 1 or 2 sensors With 1 or 2 thermostats (not possible with solar d.h.w. heating) D.h.w. control also includes the control of a circulating pump and of an electric immersion heater. The impact of the legionalla function on the circulating pump can be disabled. The d.h.w. storage tank can be forcedly charged once a day.
Remote control	 Changeover of operating mode with room unit QAW50 Overriding the major controller functions with room unit QAW70 Selection of another (programmable) operating mode with an external switch Preselection of a boiler or flow temperature setpoint with an external contact. Adjustable are the type of setpoint (constant or minimum), its action (on the heating circuit or boiler), and the flow temperature
Note on QAW70	The day of the week is set automatically with the date by the controller; an adjustment from the room unit QAW70 is not possible.

Incoming heat demand signals	The RVL482 has two separately scalable DC 010 V inputs (corresponding to $0x$ °C) to which heat demand signals from external consumers can be fed. The value of "x" can be adjusted in the range of 30130 °C.			
Communication	 Communication with other devices takes place via data bus (LPB) and allows: Signaling of heat demand to the heat source Exchange of locking and enforced signals Exchange of measured values such as outdoor temperature, return temperature, flow temperature and of clock signals Integration of heat source cascades or heat source systems (heat pump, solar panels, wood-fired boiler) Reception of heat demand signal from the SYNERGYR OZW30 central unit (with software version 3.0 or higher) Exchange of error messages 			
Error messages and flow temperature alarm	 Error messages in the event of sensor, data bus or room unit faults Flow temperature alarm; adjustable is the period of time during which the flow temperature / boiler temperature may stay outside the set limits; an error message is delivered when the set time has elapsed 			
Other functions	 One multifunctional relay. Choice of functions: Outdoor temperature switch, on / off according to the time switch, alarm contact in the event of error messages, on / off according to the occupancy time, on / off according to the occupancy time including optimization, on / off according to heat demand, on / off manually Display of parameters, actual values, operating states and error messages Simulation of outdoor temperature Relay test; all relays can be controlled manually Sensor test; all measured values from sensors and thermostats can be displayed Testing the contacts connected to terminals H1–M and H2–M Outdoor temperature-dependent frost protection for the plant; a minimum flow temperature is maintained; its setpoint and the response threshold can be adjusted Pump overrun to prevent the buildup of heat Periodic pump run (pump kick) to prevent seizing of the pumps in the summer Controller hours run meter 			
	 For more detailed information about data bus (LPB), refer to the following pieces of documentation: Data Sheet Basic System Data LPB: N2030 Data Sheet Basic Engineering Data L BP: N2022 			

Data Sheet Basic Engineering Data LPB: N2032



- 1 Operating mode buttons (selected button is lit)
- 2 Display (LCD)
- Buttons for operating the display: 3
- Prog = selection of operating line
 - + = adjustment of displayed value
- 4 Button for "Close heating circuit mixing valve" or reduce modulation, or burner stage 2 ON/OFF in manual operation
- Button for "Open heating circuit mixing valve" or increase modulation in manual operation 5
- Button for manual operation 6
- 7 LEDs for:
 - 7111 Manual operation
 - △ / ▲ Heating circuit mixing valve opens / burner modulation actuator opens / burner stage 1 ON
 - □ / ▼ Heating circuit mixing valve closes / burner modulation actuator closes / burner stage 2

 - ON
- Pump runs 8 Button for d.h.w. heating ON/OFF (ON = button lit)
- Sealing facility in the cover 9
- 10 Info button for the display of actual values
- Setting slider for flow temperature setpoint at an outside temperature of -5 °C 11
- 12 Setting slider for flow temperature setpoint at an outside temperature of 15 °C
- Setting knob for readjustment of room temperature 13
- Fixing screw with sealing facility 14

The RVL482 consists of controller insert, which accommodates the electronics, power section, output relays and - on the unit front - all operating elements, and base with the connection terminals. The operating elements are located behind a lockable transparent cover.

The operating instructions can be inserted in the transparent cover.

All values are read in the display (LCD) featuring background lighting.

The controller insert is secured to the base with 2 screws, one of which can be sealed. The cover can also be sealed.

The RVL482 can be mounted in 3 different ways:

- Wall mounting (on a wall, in the control panel, etc.)
- Rail mounting (on a top hat rail)
- Flush panel mounting (control panel door, etc.)

Analog operating elements	 Buttons for selecting the operating mode Button for d.h.w. heating on/off Info button Direct setting of heating curve by means of the little bar (only if analog setting is selected) Knob for manual readjustment of the room temperature 3 buttons for manual operation and for manual positioning commands
Digital operating elements	Entry or readjustment of all setting parameters, activation of optional functions and reading of actual values and states is made according to the operating line principle. An operating line with an associated number is assigned to each parameter, each actual value and each function that can be selected. One pair of buttons is used to select an operating line and one pair to readjust the display.
Notes	
Engineering	 The wires of the measuring circuits carry extra low voltage Those to the actuators and the pumps carry AC 24230 V The local safety regulations must be complied with Sensor cables must not be run parallel to mains carrying cables for loads such as actuator, pump, burner, etc. (insulation class II EN 60730)
Commissioning	The plant type must be configured.
Disposal	
	In terms of disposal, the RVL482 are classified as electronic scrap conforming to the European Directive 2002/96/EG (WEEE) and must not be disposed of as domestic waste. The relevant national legal requirements must be complied with and the units must be disposed of through the relevant channels. Local and currently valid legislation must be observed.

Warranty

When using the RVL482 together with third-party devices not specifically mentioned, correct functioning must be ensured by the user. In that case, Siemens will assume no responsibility for service and warranty.

Technical Data

Power supply	Rated operating voltage	AC 230 V (±10 %)		
	Frequency	50 Hz		
	Power consumption (no external load)	max. 9 VA		
	Supply line fusing	10 A		
	Switching consoity	AC 24 220 V	,	
Output relays	Switching capacity	AC 24230 V		
	Switching current OF O2 O2 O4 KG	AC 0.022 (2) A	
	Switching current of ignition transformer	AC 0.021 (1	<u>) A</u>	
	Rated current of ignition transformer		(.30 s)	
	Switch-on current of ignition transformer	max. 10 A (ma	ax. 10 ms)	
Permissible cable	Copper cable 0.6 mm \varnothing	20 m		
lengths to sensors	Copper cable 0.5 mm ²	50 m		
and room unit	Copper cable 1.0 mm ²	80 m		
	Copper cable 1.5 mm ²	120 m		
Connection terminals	Screw terminals for wire section	up to 2.5 mm ²		
		•		
Communication	Bus protocol/type	LPB		
by wire	Bus loading characteristic E	9		
Backup	Backup of controller clock	12 h		
Standards	CC-conformance to	2004/108/50		
		2004/108/EC - EN 61000-6-1 / -2		
	– Emissions	– EN 61000-6-3 / -4		
	Low voltage directive	2006/95/EC		
	– Safety	– EN 60730-1 / EN 60730-2-9		
Protective data	Safety class	II to EN 60730		
	Degree of protection (cover closed)	IP42 to EN 60529		
	Degree of contamination	2 to EN 60730		
Dimensions		refer to "Dimensions"		
Weight	Unit (net)	1.2 kg		
		0		
Colors	Controller insert	Light grey RAL 7035		
	Terminal base	Pigeon blue RAL 5014		
			I	
Environmental		Operation	Transport	Storage
conditions		EN 60721-3-3	EN 60721-3-2	EN 60721-3-1
	Climatic conditions	class 3K5	class 2K3	class 1K3
	Temperature	0+50 °C	–25…+70 °C	–20…+65 °C
	Humidity	<95 % r.h.	<95 % r.h.	<95 % r.h.
		(non-condensing)		(non-condensing)
	Mechanical conditions	class 3M2	class 2M2	class 1M2
	Use above sea level	max. 3000 m a	above sea leve	

Connection diagrams

Low voltage side

Basic connections for plants with external heat demand signals







Mains voltage side

Basic connections for plants with 2-stage burner



Basic connections for plants with modulating burner



- A6 Room unit
- B1 Flow sensor
- B2 Boiler sensor
- B3 Flow sensor for d.h.w.
- B31 D.h.w. storage tank sensor / control thermostat 1
- B32 D.h.w. storage tank sensor / control thermostat 2
- B5 Room sensor
- B6 Collector sensor
- B7 Return sensor
- B9 Outside sensor
- E1 2-stage or modulating burner
- F1 Limit thermostat
- F2 Safety limit thermostat
- LPB Data bus

- M1 Circulating pump / bypass pump
- M2 Heating circuit pump M3 Charging pump
 - 13 Charging pump
- M4 Boiler pump / circulating pump
- N1 Controller RVL482
- S1 Remote operation for operating mode
- S2 Remote operation for the flow temperature setpoint
- M5 Collector pump
- U1 Solar impact sensor
- U2 Wind sensor
- Y1 Actuator heating circuit
- Y7 Actuator d.h.w. circuit or return temperature mixing valve
- ¹) Multifunctional output

Dimensions



Dimensions in mm

© 2008 Siemens Switzerland Ltd Subject to alteration