## **XU2S18PP340DR**

light curtain receiver XU2-S - detection of body - 750..1200 mm - 12..24 V





#### Main

Range of product	Preventa Safety detection
Product or component type	Safety thru-beam receiver photo-electric sensors
Device short name	XU2S
Product compatibility	XPSCM1144 XPSCM1144P
Output type	1 safety outputs OSSD PNP
[Sn] nominal sensing distance	8 m

Complementary

Detection system	Transmitter-receiver system	
[Us] rated supply voltage	1224 V DC (1030 V) against reverse polarity	
Current consumption	<= 35 mA no-load	
Line of sight type	Along case axis	
Electrical connection	1 male connector M12 4 pins	
Tightening torque	24 N.m fixing nut 2 N.m connector	
Marking	CE	
Material	Case : nickel plated brass Lenses : PMMA (polymethyl methacrylate)	
Product weight	0.08 kg	

## Environment

Ambient air temperature for operation	-2555 °C
Ambient air temperature for storage	-4070 °C
IP degree of protection	IP67 conforming to EN/IEC 60529
Shock resistance	30 gn (3 axes : 3 times) conforming to EN/IEC 60068-2-27
Vibration resistance	7 gn (f = 1055 Hz) conforming to EN/IEC 60068-2-6


## Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 1440 - Schneider Electric declaration of conformity
REACh	Reference not containing SVHC above the threshold

# Product data sheet **Dimensions Drawings**

# XU2S18PP340DR

## **Dimensions**




- LED
- (1) (2) Potentiometer


## Wiring Schemes (3-wire DC)

#### Receiver

Light switching (no object present). PNP output



Dark switching (no object present). PNP output



#### Connector Pin View



- (1) (+
- (2) Programming
- (3) (-)
- (4) Output

## Connecting to a Safety Module




- 1: Click on Download & Documents
- 2: Click on System user guide

To have all connection schematics concerning our safety module, select "download and document" and download the file "Connecting to a monitoring device XU2S"

# XU2S18PP340DR


#### Curves

## Infrared Detection Curve



(1) Ø of beam

## **Verification of Correct Operation**



- LED off (1)
- (2) (3) (4) (5) LED on
- Red LED
- Signal level
- Optimum alignment